

# FIELD INSPECTION REPORT

|                         |                                                                                                                      |               |                                                                                   |
|-------------------------|----------------------------------------------------------------------------------------------------------------------|---------------|-----------------------------------------------------------------------------------|
| Date of Inspection :    | 17.12.2020                                                                                                           | District :    | Munger                                                                            |
| Division :              | Kharagpur - Torapur                                                                                                  | Length (Km) : | 2.500 km                                                                          |
| Name of the Road :      | PWD Kharagpur. Bariyarpur Se Bhaudam Patti                                                                           |               |                                                                                   |
| Scheme/Programme :      | MAINTENANCE MR(3054) old                                                                                             |               |                                                                                   |
| Package No. :           |                                                                                                                      | Road Id No. : | 20903808052                                                                       |
| Status of the Project : | Ongoing/Completed/Under Maintenance                                                                                  |               |                                                                                   |
| Work is a case of :     | New Connectivity/Up gradation/Maintenance                                                                            |               |                                                                                   |
| Sl. No.                 | Parameters to be checked                                                                                             | Remarks       |                                                                                   |
| 1                       | <b>Pavement</b>                                                                                                      |               |                                                                                   |
| a)                      | Road Junction condition                                                                                              | ✓S/U          |                                                                                   |
| b)                      | Condition of Surfacing                                                                                               | ✓S/U          | Erosion of Bit at few stretch from start of concrete in cc. bit last 10m visible. |
| c)                      | Riding Quality                                                                                                       | ✓S/U          |                                                                                   |
| d)                      | Road Camber                                                                                                          | ✓S/U          |                                                                                   |
| e)                      | Whether free from defects such as visible cracks, exposed aggregates in case of CC Pavement.                         | ✓Yes/No       | Some cracks visible in last 10m visible.                                          |
| f)                      | Contraction Joints provided or not (CC Pavement)                                                                     | ✓Yes/No       |                                                                                   |
| g)                      | Compaction of flank/slope & raincuts if any                                                                          | Yes/No        |                                                                                   |
| 2                       | <b>Cross Drainage</b>                                                                                                |               |                                                                                   |
| a)                      | Condition of head walls in Hume pipe culverts including its painting                                                 | S/SRI/U       | NA                                                                                |
| b)                      | Condition of Abutment & Wing walls, Slab in RCC culverts                                                             | S/SRI/U       | NA                                                                                |
| c)                      | Condition of railings/slab/approach for Bridges                                                                      | S/SRI/U       | NA                                                                                |
| 3                       | <b>Road Furniture</b>                                                                                                |               |                                                                                   |
| a)                      | Whether sign boards/informatory/cautionary board/Km & 200m stones/Pavement road markings are provided and maintained | Yes/No        |                                                                                   |
| 4                       | <b>Compliance History</b>                                                                                            |               |                                                                                   |
| a)                      | Status of ATR's & any others                                                                                         | NA            |                                                                                   |

Overall Rating :

|                                             |     |
|---------------------------------------------|-----|
| Satisfactory (S)                            | /   |
| Satisfactory but requires Improvement (SRI) | SRI |
| Unsatisfactory (U)                          | /   |

NAME : RAJIVRANJAN KR  
DESIGNATION : EE

*Ranjana*  
(Signature) 17/12/2020