

कार्यपालक अभियंता का कार्यालय
ग्रामीण कार्य विभाग, कार्य प्रमंडल, औरंगाबाद।
Email ID:-eerwdaurangabad1@gmail.com

पत्रांक..... 2580 औरंगाबाद/दिनांक..... 23.06.2020

प्रेषक,

कार्यपालक अभियंता,
ग्रामीण कार्य विभाग,
कार्य प्रमंडल, औरंगाबाद।

सेवा में,

नोडल पदाधिकारी (MR 3054)
ग्रामीण कार्य विभाग
पटना, बिहार


विषय :- नई अनुस्क्षण नीति-2018MR (3054) योजना के अंतर्गत पथ में कराये गये कार्य के विरुद्ध आवंटन उपलब्ध कराने के संबंध में।

महाशय,

उपरोक्त विषय के संबंध में सूचित करना है कि नई अनुस्क्षण नीति-2018 MR (3054) योजना के अंतर्गत पथ में कराये गये कार्य के लिए संवेदक को भुगतान करने हेतु अधियाचना विहित प्रपत्र में भरकर आवश्यक कार्यवाही हेतु समर्पित की जाती है।

अनु :- यथोक्त।

विश्वासभाजन



कार्यपालक अभियंता,
ग्रामीण कार्य विभाग,
कार्य प्रमंडल, औरंगाबाद

OFFICE OF EXECUTIVE ENGINEER, RURAL WORKS DEPARTMENT, WORKS DIVISION, Aurangabad

Requisition Format for Scheme Head- MR(3054) under Bihar Rural Road Maintenance Policy-2018 (Initial Rectification and Surface Renewal)

Name of Works Division: Aurangabad

Memorandum of Understanding																			
Sl. No.	Package No M/R-N/ 2019- Aurang abad/	Name of Road	Project ID as per MIS	Administrative Approval (AA) Letter No & Date	Administrative Approval (AA)		Agreement Amount (In Lakh)		Agreement No& Date	Date of Completion as per Agreement	Actual Date of Comple tion	Value of IRI (in mm/ km)	SDGC BM		Previous Total Allotted Amount (in Lakh)	up-to-date expenditure as per MIS (in Lakh)	Regulation against work done (in Lakh)	Remarks	
					Length (in km)	Amount of (in Lakh)	Initial Rectificatio n with Surface Renewal (in Lakh)	5 Year Routine Maintena nce (in Lakh)					Thickness of Bitumen Layer (in mm)	Value of Bitumen Content in Percentage					
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	
1	2	Rajoi Via.Dosma- Bel Barahi	NEA22000 41	Letter No. 3140 Date 22.07.2019	6.370	303.11000	272.80000	59.65000	59MBD/20 19-20 Date 04.02.2020	03.11.2020	-	2115	25 50 BM	5.08 3.34 BM	0.00000	0.00000	272.80000	Ongoing	
2	8	Nabhinagar road to Khaira	106028020 74	Letter No. 3140 Date 22.07.2019	4.883	123.62000	111.26000	43.75000	60MBD/20 19-20 Date 05.02.2020	04.11.2020	-	3715	25	5.05	0.00000	0.00000	111.26000	Ongoing	
3	16	Deo more road to Upardaha	106028021 11	Letter No. 3140 Date 22.07.2019	2.460	58.40000	52.46000	23.010	71MBD/20 19-20 Date 15.02.2020	14.11.2020	-	3715	25	5.11	0.00000	0.00000	52.46000	Ongoing	
4	14	Const. of Road from Deo Jawa Bigda to Silarh Khurd	106028010 05	Letter No. 3140 Date 22.07.2019	1.000	28.28000	25.45000	9.400	71MBD/20 19-20 Date 14.02.2020	13.11.2020	-	3715	25	5.08	0.00000	0.00000	25.45000	Ongoing	
		Total															461.97000		

Executive Engineer
Rural Works Department
Works Division, Aurangabad



OM SAI CONSULTANTS

(AN ISO 9001:2015 & ISO/IEC 17025: 2017 CERTIFIED NABL ACCREDITED LAB)
Address: - Bank of India Colony, Near Jai Shree Gas Godown, South D/SS,
P.O.-B.V. College Raja Bazaar, Patna-800014, Contact No. +919472909287
Email- omsaiconsultantspatna@gmail.com Doc. No.: OSC/7.8/F-01

TEST REPORT

Issue To:
EXECUTIVE ENGINEER
R.W.D. WORKS DIVISION, AURANGABAD

Report No.: OSC/BR/160620/05
Date of Receiving: 14/06/2020
Testing Period: 14/06/2020 TO 16/06/2020
Date of Reporting: 16/06/2020

Project Name: CONSTRUCTION OF ROAD FROM RAJOI VIA DOSHMA BEL BARAHI, (3054).

Sample Description: Semi Dense Bituminous Concrete (S.D.B.C.)

Sample Condition: Good (Packed in Bag).

Letter No.: 2450, Dated: 13/06/2020

BITUMEN CONTENT TEST

S. No.	Test Parameter	Test Method	Result	Requirements MORTH Specification Table- 500- 15	Conformity
1.	Binder Content (%)	IRC SP-11	5.08	5.0 Min	Yes

.....End of Report.....

Handwritten signature
23/6/2020
A-E

Handwritten signature
23-6-20
E-E

Handwritten signature

Checked By

Handwritten signature
OM SAI CONSULTANTS

Authorized Signatory



OM SAI CONSULTANTS

(AN ISO 9001:2015 & ISO/IEC 17025: 2017 CERTIFIED NABL ACCREDITED LAB)
Address: - Bank of India Colony, Near Jai Shree Gas Godown, South D/SS,
P.O.-B.V. College Raja Bazaar, Patna-800014, Contact No. +919472909287
Email- omsaiconsultantspatna@gmail.com Doc. No.: OSC/7.8/F-01

TEST REPORT

Issue To:
EXECUTIVE ENGINEER
R.W.D. WORKS DIVISION, AURANGABAD.

Report No.: OSC/BR/160620/06

Date of Receiving: 14/06/2020

Testing Period: 14/06/2020 TO 16/06/2020

Date of Reporting: 16/06/2020

Project Name: CONSTRUCTION OF ROAD FROM RAJOI VIA DOSHMA BEL BARAHI, (3054).

Sample Description: Bituminous Macadam (B.M.)

Sample Condition: Good (Packed in Bag).

Letter No.: 2450, Dated: 13/06/2020.

BITUMEN CONTENT TEST

S. No.	Test Parameter	Test Method	Result	Requirements MORTH Specification Table- 500-7	Conformity
1.	Binder Content (%)	IRC SP-11	3.34	3.3 Min.	Yes

.....End of Report.....

Handwritten signature
23.6.2020
A.E.

Handwritten signature
23.6.20
B.E.

Handwritten signature
Checked By



Authorized Signatory

1. The result listed refers only to the tested samples and applicable parameters endorsement of product is neither inferred nor implied.
2. Total liability of our Lab. Is limited to the invoiced amount.
3. Samples will be destroyed after 90 days from the date of issue of test report.
4. This report is not to be reproduced wholly or in part and cannot be used as an evidence in the court of law and should not be used in any advertising media without our special permission in writing.

NABL ACCREDITED
LABORATORY

Name of Road:- Rajai Bel Barahi via Dosma

Date	Time	Section No.	Length in km	Bumps in mm	Speed Rate	OR mm/km	IRI mm/km	CATEGORY ROAD	Latitude	Longitude	Event
18/6/20	10:49:0	90	0.1	260	0	2600	3015	G	24.835585	84.48177	Normal
18/6/20	10:49:40	90	0.1	160	10.1	1600	2015	G	24.83645	84.48175	Normal
18/6/20	10:52:26	90	0.1	310	0	3100	2015	G	24.83734	84.481902	Normal
18/6/20	10:53:2	90	0.1	180	10.1	1800	2215	G	24.838148	84.482222	Normal
18/6/20	10:53:37	90	0.1	160	10.1	1600	2015	G	24.839058	84.482305	Normal
18/6/20	10:54:0	90	0.1	170	10.1	1700	2115	G	24.839947	84.482473	Normal
18/6/20	10:54:12	90	0.1	170	20.2	1700	2115	G	24.840802	84.482625	Normal
18/6/20	10:54:12	90	0.1	180	10.1	1800	2215	G	24.841635	84.482962	Normal
18/6/20	10:55:0	90	0.1	170	10.1	1700	2215	G	24.84148	84.483938	Normal
18/6/20	10:55:23	90	0.1	190	10.1	1900	2115	G	24.8413	84.484915	Normal
18/6/20	10:56:0	90	0.1	140	10.1	1400	2315	G	24.842013	84.485353	Normal
18/6/20	10:56:0	90	0.1	210	10.1	2100	1815	G	24.842872	84.485487	Normal
18/6/20	10:57:0	90	0.1	220	10.1	2200	2515	G	24.843793	84.485638	Normal
18/6/20	10:57:9	90	0.1	180	10.1	1800	2615	G	24.844712	84.485673	Normal
18/6/20	10:57:44	90	0.1	190	20.2	1900	2215	G	24.845568	84.485875	Normal
18/6/20	10:58:0	90	0.1	180	20.2	1800	2315	G	24.846482	84.48579	Normal
18/6/20	10:58:19	90	0.1	180	20.2	1800	2215	G	24.847363	84.485925	Normal
18/6/20	10:58:19	90	0.1	170	20.2	1700	2215	G	24.84828	84.48616	Normal
18/6/20	10:58:54	90	0.1	180	20.2	1800	2115	G	24.849143	84.486397	Normal
18/6/20	10:59:0	90	0.1	230	10.1	2300	2215	G	24.850047	84.487	Normal
18/6/20	10:59:30	90	0.1	150	10.1	1500	2715	G	24.85072	84.486278	Normal
18/6/20	11:0:0	90	0.1	190	10.1	1900	1915	G	24.851597	84.486463	Normal
18/6/20	11:0:5	90	0.1	200	10.1	2000	2315	G	24.852507	84.486648	Normal
18/6/20	11:0:40	90	0.1	180	10.1	1800	2415	G	24.853385	84.48682	Normal
18/6/20	11:0:40	90	0.1	170	20.2	1700	2215	G	24.854307	84.486935	Normal
18/6/20	11:1:0	90	0.1	160	20.2	1600	2115	G	24.855165	84.48712	Normal
18/6/20	11:1:16	90	0.1	200	10.1	2000	2015	G	24.856052	84.487322	Normal
18/6/20	11:1:51	90	0.1	320	10.1	3200	2415	G	24.856547	84.487928	Normal
18/6/20	11:2:0	90	0.1	240	10.1	2400	3615	G	24.856697	84.48838	Normal
18/6/20	11:2:26	90	0.1	180	20.2	1800	2815	G	24.857423	84.48845	Normal
18/6/20	11:2:26	90	0.1	170	20.2	1700	2215	G	24.858208	84.488215	Normal
18/6/20	11:3:1	90	0.1	190	20.2	1900	2115	G	24.85871	84.488888	Normal
18/6/20	11:3:1	90	0.1	170	20.2	1700	2315	G	24.859205	84.489628	Normal
18/6/20	11:3:37	90	0.1	130	10.1	1300	2115	G	24.85999	84.490168	Normal
18/6/20	11:4:12	90	0.1	200	20.2	2000	1715	G	24.8607	84.49069	Normal
18/6/20	11:4:12	90	0.1	200	20.2	2000	2415	G	24.86062	84.4917	Normal
18/6/20	11:4:47	90	0.1	220	20.2	2200	2415	G	24.860473	84.492677	Normal
18/6/20	11:5:0	90	0.1	190	20.2	1900	2615	G	24.86012	84.492677	Normal
18/6/20	11:5:23	90	0.1	270	10.1	2700	2315	G	24.859907	84.493618	Normal
18/6/20	11:5:23	90	0.1	150	10.1	1500	3115	G	24.85992	84.494578	Normal
18/6/20	11:6:0	90	0.1	140	10.1	1400	1915	G	24.85992	84.495353	Normal
18/6/20	11:6:33	90	0.1	190	10.1	1900	1815	G	24.860612	84.494747	Normal
18/6/20	11:6:33	90	0.1	190	20.2	1900	2315	G	24.861453	84.494443	Normal
18/6/20	11:7:8	90	0.1	150	20.2	1500	1915	G	24.862358	84.494493	Normal
18/6/20	11:7:8	90	0.1	190	20.2	1900	2315	G	24.86327	84.494545	Normal
18/6/20	11:7:8	90	0.1	170	20.2	1700	2115	G	24.864207	84.494562	Normal
18/6/20	11:8:0	90	0.1	190	20.2	1900	2315	G	24.865087	84.494595	Normal
18/6/20	11:8:19	90	0.1	210	10.1	2100	2515	G	24.866043	84.494713	Normal
18/6/20	11:8:19	90	0.1	190	20.2	1900	2315	G	24.86693	84.494628	Normal
18/6/20	11:8:54	90	0.1	190	20.2	1900	2315	G	24.867818	84.494763	Normal
18/6/20	12:28:30	92	0.1	160	20.2	1600	2015	G	24.868565	84.495302	Normal
18/6/20	12:29:5	92	0.1	230	0	2300	2715	G	24.8692	84.496077	Normal
18/6/20	12:29:40	92	0.1	270	0	2700	3115	G	24.832688	84.48202	Normal
18/6/20	12:30:15	92	0.1	200	10.1	2000	2415	G	24.831958	84.4818	Normal
18/6/20	12:30:15	92	0.1	200	10.1	2000	2415	G	24.831085	84.481632	Normal
18/6/20	12:31:0	92	0.1	220	10.1	2200	2615	G	24.830192	84.481497	Normal
18/6/20	12:31:26	92	0.1	230	10.1	2300	2715	G	24.82941	84.481582	Normal
18/6/20	12:31:26	92	0.1	220	10.1	2200	2615	G	24.82917	84.482542	Normal
18/6/20	12:32:1	92	0.1	230	10.1	2300	2715	G	24.82862	84.483147	Normal
18/6/20	12:32:1	92	0.1	190	10.1	1900	2315	G	24.8281	84.483787	Normal
18/6/20	12:32:36	92	0.1	260	10.1	2600	3015	G	24.82803	84.48478	Normal
18/6/20	12:33:0	92	0.1	170	20.2	1700	2115	G	24.827275	84.484865	Normal
18/6/20	12:33:0	92	0.1	260	10.1	2600	3015	G	24.826365	84.484578	Normal
18/6/20	12:33:0	92	0.1	260	10.1	2600	3015	G	24.825495	84.484292	Normal
Total Length			6.300								

$$Y = 0 * X^2 + 1.000 * X + 415.2$$

$$X = 1700$$

$$Y = 2115$$

(R) RURAL ROAD


Good Average Poor
 <4000 4001-5000 >5001

16/6/2020

23.6.20

File : C:\Users\BRRDA67\Desktop\Bump\14051123.Xls, Section No. : 92, Eqn : $Y = 0 \cdot X^2 + 0.984 \cdot X + 510.7$

Name of Customer : MITUL KUMAR SINGH, Name of Work/ Road : ROJAI BEL BARAHI VIA DOSMA, Lab Job



[Signature]
23.6.20
A.E.