

Date of Inspection : 02.08.2021 District: Motihari
 Division : Chakia Length (km): 1.822
 Name of the Road: Sarothar to Sarothar NHPC Road via High School
 Scheme/Programme: MMGSY (Gen)

Sl. No.	Parameters to be checked	Remarks (S/U)
1.	Pavement	
a)	Condition of Surfacing	U
b)	Riding Quality	U
c)	Road Camber	.
d)	Whether free from defects such as visible cracks, exposed aggregates in case of CC Pavement.	
e)	Contraction Joints provided or not (CC Pavement)	S
f)	Compaction of flank/slope & raincuts if any	—

Observation Remarks:- At many stretches surface condition is poor, pot holes found & Brick-bat used in place of S/M Grd.

2.	Cross Drainage	
a)	Condition of head walls in Hume pipe culverts including its painting	—
b)	Condition of Abutment & Wing walls, Slab in RCC culverts	—
c)	Condition of railings/slab/approach for Bridges	—
d)	Condition of Vent Clearance	—

Observation Remarks:-

3.	Road Furniture	
a)	Whether sign boards/informatory/cautionary Board/ km & 200m stones/Pavement road markings are provided and maintained	S

Observation Remarks:-

4.	Compliance History	
a)	Status of ATR's & any others	—

Overall Rating :

Satisfactory (S)/ Unsatisfactory (U)

Unsatisfactory

Name of Officer:-

Ramesh Kumar

Designature:-

EE, Reg. Lab, Sasaran

02.08.2021

(Signature)