

INSPECTION REPORT FOR ROUTINE MAINTENANCE

Name of Inspecting officer: Sri Kant Prasad.		Designation of Inspecting officer: E.E.
Date of Inspection: 18/8/2021		Division: Beland.
District: Sitamarhi Block: Beland.		Length (km): BT: 1.36 / CC: 1.875
Name of Road: Pachnaur to Sukkhi road.		Actual date of Completion: 24/5/2016
Scheme/Programme & Project ID or Package No: MR (Under 5yr Plan)		Contract/Renewal (DD/MM/YY)
Project Id - 31608008030		Name of Agency/Contractor: Gurjanandan Singh.
Name of E.E: Yogesh Chandra Mishra		
Name of A.E: Birendra Pd. Singh.		
Name of J.E: Shiv Shankar		
S.NO	Name of Item/activity to be checked	Grading (GR)
1	Pavement & Shoulders	
a)	Condition of Surfacing (Condition of Pavement including filling pot holes and patch repair etc as per clause 1904 and 1905 of the specifications.)	U
b)	Rolling Quality (Pavement condition index (5/4/3/2) as per annexure 14.7 para 14.9 of specifications manual.)	U
c)	Whether free from defects such as visible cracks, damage of edges & joints, exposed aggregates for CC Pavement.	- U
d)	Construction joints provided or not (CC Pavement)	S
e)	Composition of Shoulders/slope, planting & Vegetation clearance (Mowing up of Earthen shoulders as per clause 1903 of the specifications & Rain cuts as per clause 1902 of the specifications, Cutting of branches of trees, shrubs and trimming of grass withstands etc as per clause 1912 of the specifications.)	S
Details of observation & Remarks:		
In maximum part of BT portion damaged due to heavy rain and flood.		
2	Grass Drainage (Maintenance of culverts and cause ways as per clause 1909 and 1910 of the specifications)	
a)	Condition of abutment & Retain wall/Wing walls, Slab in RCC culverts	-
b)	Condition of Slab, railing & approach of Bridges	-
c)	Condition of House pipe, head walls in House Pipe Culverts including its painting (As per clause 1909 of the specification)	U
d)	Condition of Vent Chambers	S

Details of observation & Remarks:

C.D. painting not done.

3 Road Furniture/ Road Signage

a) Whether sign boards/informatory/cautionary Board/ Road Signs & Pavement road marking are provided and maintained. (As per clause 1911 of the specifications)
b) Maintenance of Km post/ 200m post and guard stones are maintained. (Maintenance of 200 m and kilo meter stones as per clause 1913 of the specifications.)

U

Details of observation & Remarks:

Km post, 200m post not found.

4 Compliance History

a) Status of ATR's & any others

No.

Satisfactory (S)/ Unsatisfactory (U)

U

If Overall grading is unsatisfactory then :

Action taken : grant Agency & Subordinates (if any) give details with references:

C.D.
18/8/2021
A.E.

(Signature)

18/8/2021
E.E.