

# INSPECTION REPORT FOR ROUTINE MAINTENANCE

Name of Inspecting officer	Ram Prabesh Saw (T.A.) / Sahodys Rajek (A.E.)	Designation of Inspecting officer	T A R.W.D Circle Siwan
Date of Inspection	18/08/21	Division	Begusarai
District :-	Begusarai	Block :-	matihani
Name of Road :-	L031-T01 TO MAHAMMADPUR HATMAN	Length (km):	BT: + C.C. 1.226 K.M.
Scheme/Programme & Project ID or Package No:	PMHSY 32010502090/BR-04R-210	Actual date of Completion const/Renewal (DD/MM/YY)	28.09.16
Name of E.E.	Ram Sewak Singh	Name of Agency/Contractor:	Rakesh Kumar
Name of A.E.	Om Prakash Gupta		Hatman,
Name of J.E.	Birendra Prasad.		Ratanpur, Begusarai
			RWD 3165/2012-
Sl.NO	Name of Item/activity to checked	Grading (S/U)	
1	Pavement & Shoulders		
a)	Condition of Surfacing (Condition of Pavement including filling pot holes and patch repair etc as per clause 1904 and 1905 of the specifications.)	S	
b)	Riding Quality (Pavement condition index (S/A/3/<3) as per annexure 14.7 para 14.9 of operation manual.)	—	
c)	Whether free from defects such as visible cracks, damage of edges & Joints, exposed aggregates for CC Pavement.	S	
d)	Contraction Joints provided or not (CC Pavement)	S	
e)	Compaction of Shoulders/slope, raincuts & Vegetation clearance (Making up of Earthen shoulders as per clause 1903 of the specifications & Rain cuts as per clause 1902 of the specifications, Cutting of branches of trees, shrubs and trimming of grass and weeds etc as per clause 1915 of the specifications.)	U	
Details of observation & Remarks:			
<p>Compaction of shoulder/slope not maintained. Flank E/W is required. Vegetation clearance work was in progress. Earth work in flank/shoulders is required to maintain road formation width. B.T. &amp; C.C. surface is satisfactory.</p>			
2	Cross Drainage (Maintenance of culverts and cause ways as per clause 1909 and 1910 of the specification)		
a)	Condition of abutment & Return wall/Wing walls, Slab in RCC culverts	—	
b)	Condition of Slab, railing & approach of Bridges	—	
c)	Condition of Hume pipe, head walls in Hume Pipe Culverts including its painting (As per clause 1909 of the specification)	S	
d)	Condition of Vent Clearance	S	

Details of observation & Remarks:

But painting over parapet not done.

3

Road Furniture/ Road Signage

a)

a) Whether sign boards/informatory/cautionary Board/ Road Signs & Pavement road marking are provided and maintained. ( As per clause 1911 of the specifications)  
b) Maintenance of Km post/ 200m post and guard stones are maintained. (Maintenance of 200 m and kilo meter stones as per clause 1913 of the specifications.)

S

Details of observation & Remarks:

freshly done and also it was in progress.

4

Compliance History

a)

Status of ATR's & any others

Satisfactory (S)/ Unsatisfactory (U)

If Overall grading is unsatisfactory then :

Action taken against Agency & Subordinates (if any) give details with references:

overall grading - S

(Signature)

AE  
18/8/21  
AE

18.8.21  
(Flying squad No-2)