

कार्यपालक अभियंता का कार्यालय
ग्रामीण कार्य विभाग, कार्य प्रमंडल, पालीगंज।

पत्रांक:- 1222 (अ)

पालीगंज / दिनांक:- 26/08/2021

प्रेषक,

कार्यपालक अभियंता
ग्रामीण कार्य विभाग,
कार्य प्रमंडल, पालीगंज।

सेवा में,

अपर मुख्य कार्यपालक पदाधिकारी,
सह सचिव (ब्रांडा)
ग्रामीण कार्य विभाग,
बिहार, पटना।

विषय:-MMGSY(Gen.) योजनान्तर्गत निर्माण कार्य में आवंटन हेतु अधियाचना भेजने के संबंध में।

महाशय,

उपर्युक्त विषय के संबंध में कहना है कि MMGSY(Gen.) योजनान्तर्गत पूर्ण किए गए निर्माण कार्य हेतु अधियाचना विहित प्रपत्र में तैयार कर आवश्यक कार्रवाई हेतु समर्पित किया जाता है।

अनु०-(1) अधियाना विहित प्रपत्र में।
(2) M.B का छायाप्रति।

विश्वासभाजन

कार्यपालक अभियंता
ग्रामीण कार्य विभाग,
कार्य प्रमंडल, पालीगंज

26/8/2021

Rural Works Department
MMGSY (Gen.) Allotment Requisition Format

Name of Division :- RWD Works Division, Palgamu

Sl. No.	Year	Name of Road	Name of Contractor	Administrative Sanction		Agreement Amount (in lacs)		Allotment Received (in Lacs)	Total Expenditure (in Lacs)	Value of Measurement (in Lacs)	Current Demand (in Lacs)	Remarks
				Length (in Km)	Amount (in lacs)	Main Work	Maintenance					
1	2	3	4	5	6	7	8	9	10	11	12	13
1	2016-17	Construction & Five Year Maintenance of road from Berar Nisharpura Road Berar Tola	M/s Tirupati Balajee	1.450	84.25400	69.26456	5.98532	40.7994	40.7994	66.03727	25.23787	Complete
Total				1.450	84.254	69.26456	5.98532	40.79940	40.79940	66.03727	25.23787	

Total requisitioned amount Rs 25.23787 Lacs (Rs Twenty Five lacs Twenty Three Thousands Seven Hundred Eighty Seven Only)

Executive Engineer
RWD Works Division, Palgamu

[Signature]
26/6/2021

No. 423

OFFICE OF THE EXECUTIVE ENGINEER
REGIONAL LABORATORY, R. W. D., GULZARBAGH, PATNA - 7
CONCRETE CURE TEST RESULT

Date 16/03/2021

Name of Work/Project :- Bear Nisharpur Road Bear 70/4.

Name of Scheme:- M.M.Sy (Cau)

Name of Agency:- M/S Tripathi Balaji

Name of Sample:- Concrete Cube M30

Package No./Agreement No.:- 09/505/M.M.Sy/2016-17

Date of Collection/Received in Lab.:- 13-03-2021
Date Of Test:- 16-03-2021

EE/AL: RWD Works Div./Sub Div. ----- vide Itr. No. -----
SICAL TEST -----

Description										Test 7/28 Days	
Date of Concreting	Member Under Construction	Proportion Of Mix/Grade	Identification Of Marks	Date of test	Area of mould (cm ²)	Load at initial Cracking (KN/Tone)	Maximum Load in (KN/Tone)	Crushing Strength in Kg/cm ²	Average Crushing Strength Kg/cm ²	Required Crushing in kg/cm ²	Remarks
2	3	4	5	6	7	8	9	10	11	12	
11-02-2021	CCP	M30	DBC-1	16-03-2021	225	630	670	303.55			
"	"	"	DBC-2	"	225	640	690	312.61	309.59	300.00	
"	"	"	DBC-3	"	225	630	690	312.61			

Submitted to/forwarded to:

R. W. D. Works Division :- Palligay

16/03/2021

A.D.

16/03/2021

A.E.

16/03/2021

E.E.

Regional Laboratory
D. Gulzarbagh Patna - 7

Regional Laboratory
R. W. D. Gulzarbagh Patna - 7

Regional Laboratory
R. W. D. Gulzarbagh Patna - 7

Regional Laboratory
R. W. D. Gulzarbagh Patna - 7

OFFICE OF THE EXECUTIVE ENGINEER

REGIONAL LABORATORY, R.W.D., GULZARBAGH, PATNA
PHYSICAL AND GRADATION TEST OF COARSE AGGREGATE

669

707/6/2021

Name of Project/Road :- Nisarpura Road To Barabar Talu
 Name of Scheme :- M.M.H.R. (A) (B)
 Name of Agency :- P.S. 754/10/10 Barabjee.
 Nature of sample :- Stone chips (13.2 mm to 5.6 mm)
 Location :- S.O.M.
 Date of Collection/Received :- 11/6/2021
 Date of Test :- 17/6/2021
 Ref :- Material sent by E.E./A.E. R.W.D. WORKS Division/Sub Division - Gulzargar
 vide letter No. 17(2021) Dt. 22-4-2021
 Agreement No / Package No. :- 09/S.R.O./R.M.457/2016-17

Sl. No.	A.J.V.	
	Average Test Value	Required Value(Max)
1.	12.7 a/	40%

Sl. No.	Sieve Size in (mm)	Total Weight of Sample Taken Kgs 18.325 kg				Required Value	Remarks
		Weight Retd.	% of Wt. Retained	% of Cum. Retained	% of Passing		
1							
2	22.4	0.000	0.00	0.00	100	12.137 kg	Stone chips 12.2 mm wt taken =
3	11.2	12.137	100.00	100.00	0	0	
4							
5	13.2	0.000	0.00	0.00	100	6.188 kg	Stone chips 5.6 mm wt taken =
6	5.6	6.188	100.00	100.00	0	0	
7	-	-	-	-	-	-	

Regional Laboratory
 D. Gulzargar
 Patna - 7

Regional Laboratory
 R.W.D. Gulzargar
 Patna - 7

Regional Laboratory
 R.W.D. Gulzargar
 Patna - 7