

FIELD INSPECTION REPORT

Date of Inspection: 09.01.2021 District: SARAN
 Division: SONPUR Length (km): 1.200
 Name of the Road: Marar Anyay Main Road to Ramdayal Sah ke Ghar Hote Hue to Late Janki Rai ke Ghar Tak
 Scheme/Programme: MMGSY SC
 Package No : Road ID No :
 Status of The Project: MAINTENANCE
 Work is a case of : Maintenance

Sl.No	Parameters to be checked	Remarks
1	Pavement	
a)	Road surface Condition	S
b)	Condition of Surfacing	S
c)	Riding Quality	S
d)	Road Camber	S
e)	Whether free from defects such as visible cracks, exposed aggregates in case of CC Pavement.	S
f)	Contraction Joints provided or not (CC Pavement)	S
g)	Condition of Flank/slopes & rain cuts if any	SRI
2	Cross Drainage	
a)	Condition of head walls in Home pipe Culverts including its painting	S
b)	Condition of Abutment & Wing Walls, Slab in RCC Culverts	S
c)	Condition of railings/slab/approach for Bridges	S
3	Road Furniture	
a)	Whether sign boards/informatory/cautionary Board/km & 200m stones/Pavement road markings are provided and maintained	S
4	Compliance History	
a)	Status of ATR's any others	NO

Overall Rating :

Satisfactory (S)	
Satisfactory but requires Improvement (SRI)	SRI
Unsatisfactory (U)	

Signature

NAME:- RAJEEV RANJAN KUMAR
 DESIGNATION: JUNIOR ENGINEER

09/01/2021