

INSPECTION REPORT FOR FLOOD /RAIN DAMAGE ROAD

Name of Scheme: Sikoti Pul - Bhairavgarh path

Hazards: Flood/Rain Flood

Division: Bagha - 1 District: West Champaran Actual Length (in km): 5.5

Damage Length (in km): 0.200 Damages Location/Chainage: 1.600 to 1.800

Name of Scheme/Programme: PMBSY

Status of Project: Under Agreement/Out of Agreement

Sr. No.	Parameters to be Checked in Restoration work	Remarks : (S/U)
1.	Pavement (BT/CC)	
a)	Condition of Surfacing	S

Description of observation : In 200m length 80mm thick MSS surface done throughout.

b) Adequate Thickness of pavement layers constructed

Description of observation : Only Pot patch with GSBgo II & WBMgo III done as and where required

c) Quality of Construction Material Used

Description of observation : MSS quality material satisfactory

d) Whether free from any defects and Irregularity example- Surface Cracks, Undulation, exposed aggregates in case of CC Pavement, Poor workmanship, etc.

Description of observation : No undulation.

e) Compaction of flanks/ slope & raincuts

Description of observation : No rain cuts

2 Cross Drainage Structure

a) Condition of head walls in Hume pipe culverts

b) Condition of Vent Clearance

c) Condition of railings/Slab/approach for Bridges

Description of observation of CD works :

Remark if any: In this road at chainage 160 to 1610m approach again damaged by rain/flood in the last month of June 2021 which is Temporarily Restored by Brick Bats and Hume pipe also placed.

Overall Rating

Satisfactory (S) / Unsatisfactory (U)

Satisfactory (S)

Name of Officer: Pankaj Kumar Singh

Designation: Executive Engineer.

(Signature)