

## INSPECTION REPORT FOR ROUTINE MAINTENANCE

Date of Inspection : 25.11.2021		District: Araria
Division : Farbigang		Length (km): 1.600
Name of the Road: SBI Mirzapur to Sonapur Sukrant House		
Scheme/Programme: GTSNY		
Sl. No.	Parameters to be checked	Remarks (S/U)
1.	Pavement	
a)	Condition of Surfacing	S
b)	Riding Quality	S
c)	Road Camber	S
d)	Whether free from defects such as visible cracks, exposed aggregates in case of CC Pavement.	S
e)	Contraction Joints provided or not (CC Pavement)	S
f)	Compaction of flank/slope & raincuts if any	U
Observation Remarks:- At some stretches flank were not proper		
2.	Cross Drainage	
a)	Condition of head walls in Hume pipe culverts including its painting	U
b)	Condition of Abutment & Wing walls, Slab in RCC culverts	-
c)	Condition of railings/slab/approach for Bridges	-
d)	Condition of Vent Clearance	S
Observation Remarks:- Painting of Head walls in Hpculvert not done.		
3.	Road Furniture	
a)	Whether sign boards/informatory/cautionary Board/ km & 200m stones/Pavement road markings are provided and maintained	U
Observation Remarks:- km & 200m stones not found		
4.	Compliance History	
a)	Status of ATR's & any others	-

Overall Rating :

Satisfactory (S)/ Unsatisfactory (U)

Satisfactory(S)

Name of Officer:-

Pranod Kumar

Designature:-

EE, RWD, R. Lab Sasaram  
EE, RWD, W.D. Farbigang - Sri Amal Prakash25.11.2021  
JE

(Signature)