

INSPECTION REPORT FOR ROUTINE MAINTENANCE

(5)

Date of Inspection : 28.11.21		District: Gaya
Division : Tikari		Length (km): 2.50 K.M
Name of the Road: Const of road from barabar main road to bajit pur.		
Scheme/Programme: NABARD (Maintenance)		
Sl. No.	Parameters to be checked	Remarks (S/U)
1.	Pavement	
a)	Condition of Surfacing	U
b)	Riding Quality	U
c)	Road Camber	-
d)	Whether free from defects such as visible cracks, exposed aggregates in case of CC Pavement.	U
e)	Contraction Joints provided or not (CC Pavement)	U
f)	Compaction of flank/slope & raincuts if any	
Observation Remarks:- At about 0.7 km chainage, B.T. surface is damaged. From 0 to 1.1 km approx, few patches have been repaired. But in the whole length, depressions, Edge erosion, wheel track etc are existing which needs repair. Compaction of flank/slope is not maintained. 1.1 to 1.5 km pcc is roughened. At curves, super-elevation is not maintained.		
2.	Cross Drainage	
a)	Condition of head walls in Hume pipe culverts including its painting	S
b)	Condition of Abutment & Wing walls, Slab in RCC culverts	-
c)	Condition of railings/slab/approach for Bridges	-
d)	Condition of Vent Clearance	S
Observation Remarks:- Not maintained.		
3.	Road Furniture	
a)	Whether sign boards/informatory/cautionary Board/ km & 200m stones/Pavement road markings are provided and maintained	U
Observation Remarks:- Not maintained.		
4.	Compliance History	
a)	Status of ATR's & any others	

Overall Rating : Satisfactory (S)/ Unsatisfactory (U) U

Name of Officer:- R.P. Sahu (E.E)

Designature:- Sahendra Rajak (A.E)

Flying Squad No. 2
(R.W.N)

28.11.21
(Signature)