

**कार्यपालक अभियंता का कार्यालय,
ग्रामीण कार्य विभाग, कार्य प्रमंडल, मनिहारी।**

पत्रांक :- 2510-

/मनिहारी, दिनांक- 07/09/2021

प्रेषक,

कार्यपालक अभियंता,
ग्रा0का0वि0, मनिहारी।

सेवा में,

अपर-मुख्य-कार्यपालक-पदाधिकारी,
BRRDA, 3री मंजिल, भूमि विकास बैंक भवन,
बिहार, पटना।

विषय :- शीर्ष New Maintenance Policy-2018 योजनान्तर्गत निर्माण हेतु आवंटन की
अधियाचना के संबंध में।

महाशय,

उपर्युक्त विषय के संबंध में कहना है कि शीर्ष New Maintenance Policy-2018
योजनान्तर्गत ग्रा0का0वि0, कार्य प्रमंडल, मनिहारी द्वारा विहित प्रपत्र में अधियाचना तैयार कर आपके
अग्रेतर कार्रवाई हेतु समर्पित की जाती है।

अनु0:-यथोक्त।

विश्वासप्रजन,
08/09/21
कार्यपालक अभियंता,
ग्रामीण कार्य विभाग,
कार्य प्रमंडल, मनिहारी।

(See Government of India's Decision (1) below Rule-150)
Form of Utilisation Certificate upto the month of September, 2021
New Maintenance Policy-2018

2. Certified that I have satisfied myself that the conditions on which the grants-in-aid was sanctioned have been duly fulfilled/are being fulfilled and that I have exercised the following checks to see that the money was actually utilized for the purpose for which it was sanctioned,

Kind of Checks exercised :-

- Works have been supervised by Executive Engineer/Superintending Engineer.
- Periodical inspection has been conducted by Executive Engineer/Superintending Engineer.
- Construction materials have been tested.
- Measurements have been recorded in the MBs and test check conducted by the Assistant.
- All other codal formalities have been observed.

Physical Progress achieved :-

- Construction of Road Works.
- Construction of CD Works.

Executive Engineer,
RWD (W) Division, Manihari

RWD, Works Division, Manihari

Requisition Format for Scheme Head - MR (3054) Under Bihar Rural Road maintenance Policy 2018 (Initial Rectification and Surface Renewal)
Name of Division : Manihari

Sl. No.	Package no.	Name of Road	Project ID as per MIS	Administrative Approval (AA) Letter No. & Date	Administrative Approval (AA)		Agreement Amount (in Lac)		Agreement No. & Date	Date of Completion as per Agreement	Actual Date of Completion	Value of IRI (in mm/km)	Thickness of Bitumen Layer (in mm)	Value of Bitumen Content in percentage	Previous Total Allocated Amount (in Lac)	up to date expenditure as per MIS (in Lac)	Requisition Against work done (in lac)	Remarks
					Length (in Km)	Amount (in Lac)	Initial Rectification with Surface Renewal (in lac)	5 years Routine Maintenance (in lac)										
1	MR-N/20-21/Manihari/09	Mehadibari-Belaunda	21105602041	666/10.02.20	5.880	235.001	145.799	76.25388	51/MBD/2020-21, 22.01.2021	21.01.2022	18.08.21	2391.64	25mm	5.1%	0.00000	0.00000	145.38241	Completed
Total															0.00000	0.00000	145.35241	

Dr. S. S. S. S.
Divisional Accounts Officer
RWD, Works Division, Manihari

M. A. A.
Executive Engineer
RWD, Works Division, Manihari

Lab Job number :93

Date :12-07-2021

Name of Customer :M/S Exim Bussiness World Centre

Name of Work/ Road :Mehandibari To Belaunda Part A

Sr.no	Location of test (in km)	Corrected U.I value (mm/km)	Road catagory
1	0.1	2303	G
2	0.2	2206	G
3	0.3	2400	G
4	0.4	2303	G
Average IRI Value		2303.00	

Aw
10/8/21

Q
10/8/21

AR
10/8/21

Lab Job number :93

Date :12-07-2021

Name of Customer :M/S Exim Bussiness World Centre

Name of Work/ Road :Mehandibari To Belaunda Part A

Date	Time	Section No.	Length in km	Bumps in mm	Speed Rate	OR mm/km	IRI mm/km	CATEGORY ROAD	Latitude	Longitude	Event
12/ 7/ 21	9: 41: 32	93	0.1	230	0	2300	2303	G	25.554347	87.782608	Curve
12/ 7/ 21	9: 41: 32	93	0.1	220	10.1	2200	2206	G	25.553668	87.781868	Normal
12/ 7/ 21	9: 42: 7	93	0.1	240	10.1	2400	2400	G	25.553320	87.78111	Normal
12/ 7/ 21	9: 42: 7	93	0.1	230	10.1	2300	2303	G	25.552657	87.78007	Normal

$$Y = 0 * X^2 + 0.969 * X + 74.60$$

$$X = 3875$$

$$Y = 3829$$

(R) RURAL ROAD


Good <4000 Average 4001-5000 Poor >5001

10/8/21

10/8/21

10/8/21

File: C:\RAM KUMAR\MISC Files\Bump integrator\Barsot DVA\Mehandibari to belounda\12071031 Part A.xls
Name of Customer: M/S Exim Business World Centre, Name of Work/Road: Mehandibari To Belounda, Lab Job



10/10/20

10/10/20

10/10/20

Lab Job number :95

Date :12-07-2021

Name of Customer :M/S Exim Bussiness World Centre

Name of Work/ Road :Mehandibari To Belaunda Part B

Sr.no	Location of test (in km)	Corrected U.I value (mm/km)	Road catagory
1	0.100	1528	G
2	0.200	1915	G
3	0.300	2497	G
4	0.400	2497	G
5	0.500	2981	G
6	0.600	2690	G
7	0.700	2690	G
8	0.800	2109	G
9	0.900	2400	G
10	1.000	2497	G
11	1.100	1915	G
12	1.200	1915	G
13	1.300	2206	G
14	1.400	2303	G
15	1.500	1624	G
16	1.600	2109	G
17	1.700	2012	G
18	1.800	2206	G
19	1.900	3272	G
20	2.000	3853	G
21	2.100	1818	G
22	2.200	2109	G
23	2.300	2109	G
24	2.400	2109	G
25	2.500	2303	G
26	2.600	2109	G
27	2.700	1528	G
28	2.800	2400	G
29	2.900	2012	G
30	3.000	2206	G
31	3.100	2206	G
32	3.200	2012	G
33	3.300	2400	G
34	3.400	3078	G
35	3.500	2497	G
36	3.600	3562	G
37	3.700	2690	G
38	3.800	3466	G
39	3.900	3562	G
40	4.000	2497	G
41	4.100	2884	G
42	4.200	2690	G
43	4.300	2593	G
44	4.400	3272	G
45	4.500	3078	G
46	4.600	2593	G
47	4.700	2303	G

12/07/21

12/07/21

12/07/21

Sr.no	Location of test (in km)	Corrected U.I value (mm/km)	Road catagory
48	4.800	2303	G
49	4.900	2593	G
50	5.000	2593	G
51	5.100	2497	G
52	5.200	2400	G
53	5.300	2303	G
54	5.400	2593	G
55	5.500	3829	G
Average IRI Value		2480.29	

Handwritten signature
10/8/21

Handwritten signature
10/8/21

Handwritten signature
10/8/21

Lab Job number :95

Date :12-07-2021

Name of Customer :M/S Exim Bussiness World Centre

Name of Work/ Road :Mehandibari To Belaunda Part B

Date	Time	Section No.	Length in km	Bumps in mm	Speed Rate	OR mm/km	IRI mm/km	CATEGORY ROAD	Latitude	Longitude	Event
12/7/21	10:12:1	95	0.100	150	0	1500	1528	G	25.55430	87.77941	Normal
12/7/21	10:12:36	95	0.100	190	10.1	1900	1915	G	25.55473	87.77865	Curve
12/7/21	10:13:0	95	0.100	250	10.1	2500	2497	G	25.55560	87.77870	Normal
12/7/21	10:13:11	95	0.100	250	10.1	2500	2497	G	25.55650	87.77874	Normal
12/7/21	10:13:11	95	0.100	300	20.2	3000	2981	G	25.55739	87.77852	Normal
12/7/21	10:13:47	95	0.100	270	20.2	2700	2690	G	25.55822	87.77832	Normal
12/7/21	10:14:0	95	0.100	270	20.2	2700	2690	G	25.55914	87.77822	Curve
12/7/21	10:14:22	95	0.100	210	20.2	2100	2109	G	25.55999	87.77855	Normal
12/7/21	10:14:22	95	0.100	240	20.2	2400	2400	G	25.56083	87.77879	Normal
12/7/21	10:14:22	95	0.100	250	20.2	2500	2497	G	25.56173	87.77897	Normal
12/7/21	10:15:0	95	0.100	190	10.1	1900	1915	G	25.56264	87.77894	Curve
12/7/21	10:15:32	95	0.100	190	10.1	1900	1915	G	25.56325	87.77842	Normal
12/7/21	10:15:32	95	0.100	220	20.2	2200	2206	G	25.56415	87.77823	Normal
12/7/21	10:16:0	95	0.100	230	20.2	2300	2303	G	25.56499	87.77785	Normal
12/7/21	10:16:8	95	0.100	160	20.2	1600	1624	G	25.56590	87.77769	Normal
12/7/21	10:16:43	95	0.100	210	10.1	2100	2109	G	25.56682	87.77776	Normal
12/7/21	10:17:0	95	0.100	200	20.2	2000	2012	G	25.56761	87.77808	Normal
12/7/21	10:17:0	95	0.100	220	20.2	2200	2206	G	25.56845	87.77847	Normal
12/7/21	10:18:0	95	0.100	330	10.1	3300	3272	G	25.56941	87.77936	Normal
12/7/21	10:18:29	95	0.100	390	10.1	3900	3853	G	25.56900	87.78020	Bridge
12/7/21	10:19:0	95	0.100	180	20.2	1800	1818	G	25.56900	87.78116	Normal
12/7/21	10:19:4	95	0.100	210	20.2	2100	2109	G	25.56888	87.78214	Curve
12/7/21	10:19:4	95	0.100	210	20.2	2100	2109	G	25.56870	87.78293	Normal
12/7/21	10:19:39	95	0.100	210	20.2	2100	2109	G	25.56840	87.78378	Normal
12/7/21	10:19:39	95	0.100	230	20.2	2300	2303	G	25.56834	87.78474	Normal
12/7/21	10:19:39	95	0.100	210	20.2	2100	2109	G	25.56818	87.78569	Normal
12/7/21	10:21:0	95	0.100	150	10.1	1500	1528	G	25.56774	87.78672	Normal
12/7/21	10:21:0	95	0.100	240	20.2	2400	2400	G	25.56895	87.78718	Normal
12/7/21	10:21:25	95	0.100	200	20.2	2000	2012	G	25.56980	87.78744	Normal
12/7/21	10:21:25	95	0.100	220	20.2	2200	2206	G	25.57063	87.78770	Normal
12/7/21	10:22:0	95	0.100	220	10.1	2200	2206	G	25.57135	87.78778	Curve
12/7/21	10:22:0	95	0.100	200	20.2	2000	2012	G	25.57144	87.78853	Normal
12/7/21	10:22:35	95	0.100	240	20.2	2400	2400	G	25.57138	87.78956	Normal

$$Y = 0 * X^2 + 0.969 * X + 74.60$$

$$X = 3875$$

$$Y = 3829$$

(R) RURAL ROAD

Good Average Poor
 <4000 4001-5000 >5001

10/10/21

10/10/21

10/10/21


Date	Time	Section No.	Length In km	Bumps In mm	Speed Rate	OR mm/km	IRI mm/km	CATEGORY		Latitude	Longitude	Event
									ROAD			
12/7/21	10:22:35	95	0.100	310	20.2	3100	3078	G		25.57137	87.79060	Normal
12/7/21	10:23:10	95	0.100	250	20.2	2500	2497	G		25.57121	87.79156	Curve
12/7/21	10:23:10	95	0.100	360	20.2	3600	3562	G		25.57200	87.79179	Normal
12/7/21	10:23:46	95	0.100	270	20.2	2700	2690	G		25.57243	87.79285	Curve
12/7/21	10:23:46	95	0.100	350	10.1	3500	3466	G		25.57262	87.79344	Curve
12/7/21	10:24:21	95	0.100	360	10.1	3600	3562	G		25.57295	87.79365	Normal
12/7/21	10:24:56	95	0.100	250	10.1	2500	2497	G		25.57313	87.79471	Normal
12/7/21	10:25:32	95	0.100	290	10.1	2900	2884	G		25.57350	87.79563	Curve
12/7/21	10:25:32	95	0.100	270	20.2	2700	2690	G		25.57393	87.79637	Normal
12/7/21	10:26:06	95	0.100	260	10.1	2600	2593	G		25.57402	87.79749	Normal
12/7/21	10:26:06	95	0.100	330	10.1	3300	3272	G		25.57388	87.79835	Culvert
12/7/21	10:26:41	95	0.100	310	20.2	3100	3078	G		25.57362	87.79931	Normal
12/7/21	10:26:41	95	0.100	260	20.2	2600	2593	G		25.57388	87.80023	Normal
12/7/21	10:27:16	95	0.100	230	20.2	2300	2303	G		25.57315	87.80116	Normal
12/7/21	10:27:51	95	0.100	230	10.1	2300	2303	G		25.57296	87.80198	Normal
12/7/21	10:27:51	95	0.100	260	20.2	2600	2593	G		25.57270	87.80296	Normal
12/7/21	10:28:27	95	0.100	260	10.1	2600	2593	G		25.57245	87.80390	Normal
12/7/21	10:29:02	95	0.100	250	10.1	2500	2497	G		25.57224	87.80494	Curve
12/7/21	10:29:02	95	0.100	240	10.1	2400	2400	G		25.57219	87.80589	Normal
12/7/21	10:29:37	95	0.100	230	20.2	2300	2303	G		25.57220	87.80684	Curve
12/7/21	10:30:08	95	0.100	260	20.2	2600	2593	G		25.57228	87.80758	Normal
12/7/21	10:30:52	95	0.080	310	10.1	3875	3829	G		25.57278	87.80826	Normal

01/01/21

2/1/21

12/7/21

File: C:\RAM KUMAR\MISC Files\Bump integrator\Baisol Dr\Mehandibari to belounda\12071031 Part B.xls
 Name of Customer: M/S Exam Bussiness World Centre, Name of Work/ Road: Mehandibari To Belounda, Lab Job



Mr. Baisol

Mr. Baisol

Mr. Baisol

**कार्यपालक अभियंता का कार्यालय,
ग्रामीण कार्य विभाग, क्षेत्रीय प्रयोगशाला, पूर्णियाँ।**

पत्रांक.....559...../दिनांक 05-08-2011

प्रेषक,

कार्यपालक अभियंता,
ग्रामीण कार्य विभाग,
क्षेत्रीय प्रयोगशाला, पूर्णियाँ।

सेवा में,

कार्यपालक अभियंता,
ग्रामीण कार्य विभाग,
कार्य प्रमंडल **प्रतिहरी।**

विषय :-

निर्माण कार्यों प्रयुक्त होने वाली सामग्रियों के नमूने की जाँच कर जाँच फल प्रतिवेदन भेजने के संबंध में।

महाराज,

उपर्युक्त विषय के संबंध में सूचित करना है कि निर्माण कार्यों में प्रयुक्त होनेवाली सामग्रियों के नमूने की जाँच कर जाँचफल प्रतिवेदन आपके आवश्यक कार्रवाई हेतु भेजी रही है।

क्र० सं०	पथ नाम	योजना का नाम	नमूने का जाँचफल
1.	Maint-7 road from Singhaul to Sakandha road	MR/3054	G.S.B-II, W.B.M.C.V III S.D.B.C (Mix) Sample.
2.	Maint-7 road from Mehudibari to Belunda Road.	MR/3054	G.S.B-II, W.B.M.C.V III S.D.B.C (Mix) Sample.

अनु०-यथोक्त।

[Signature]
10/8/11

[Signature]
10/8/11

[Signature]
10/8/11

विश्वासभाजन

[Signature]
05/08/2011

कार्यपालक अभियंता,
ग्रामीण कार्य विभाग,
क्षेत्रीय प्रयोगशाला, पूर्णियाँ
05/08/2011

OFFICE OF THE EXECUTIVE ENGINEER R.W.D. REGIONAL

LABORATORY, PURNER, (BIHAR)

RESULT OF BITMEN CONTENT OF MIX SAMPLE

Name of work Maint road from singhauli to Name of Division Manikheri
Salkandha road
 Package no./ngt.no. MRI 3054 Name of Agency Exim Business world center
 Sample Collected by A.E.R.W.D. (w) dlv. Manikheri
 Location 500 M. Wt. of sample taken 1000gms.

SDBC

Sl.No.	Sample No.	Identification No.	Wt. of sample b.c.	Wt. of sample a.c.	Loss wt.	Average	% of bitmen content	Remarks
1.	P.	S1	330	314.0	16.0			
2.	Q	S2	321	305	16.0	15.33	5.09%	
3.	R	S3	298	284	14.0			

Copy to Executive Engineer RWD (w) dlv. Manikheri

Supitending Engineer _____

Chief Engineer Bihar Patna _____

Kgnot
LA 5/8/21

10/8/21

10/8/21

10/8/21

05/08/2021
 EXECUTIVE ENGINEER
 RURAL WORKS DEPT.
 REGIONAL LABORATORY
 PURNEA.

RURAL WORKS DEPARTMENT, REGIONAL LABORATORY, PURNEA

NAME OF THE ROAD - Maint Road from Singhaur to Solkandig road.

PACKAGE NO. UNDER P.M.G.S.Y. MR/3054

NAME OF THE WORKS DIVISION Mawikari

NAME OF WORK: WBM W II

NAME OF WORKS CIRCLE Purney

NATURE OF SAMPLE: Stainless steel w/ III

SAMPLE COLLECTED BY: *A.F.R.W. D.W. US 21 Jannagar*

NAME OF AGENCY: Exim Business world center

LOCATION: S02M

SIEVE ANALYSIS FOR GRADATION OF Stone metal w/ III
WEIGHT OF SAMPLE TAKEN 12.7 Kg.

LETTER NO.

DATE :-

COPY TO:

E.E.R.V.D. WORKS DIVISION *Mari Kan*

S.E.R.V.D. WORKS CIRCLE

S.E. CUM STATE QUALITY CO-ORDINATOR, BIHAR, PATNA

CHIEF ENGINEER, R.W.D. BIHAR, PATNA

LA 5/28/21

REGIONAL LABORATORY
R.W.D. PURNEA

REGIONAL LABORATORY,
BOW D. PUENEA

EXECUTIVE ENGINEER,
REGIONAL LABORATORY.
R.W.D. PURNEA

**OFFICE OF THE EXECUTIVE ENGINEER
REGIONAL LABORATORY
RURAL WORK DEPARTMENT, PURNEA
GRADATION FOR GRANULAR SUB BASE MATERIAL**

- 1) Name of Work: Mahat Road from singhaur to solkandha Road.
 2) Name of scheme: MR/3054
 3) Name of Agency: Exim Business world center.
 4) Sample Collected by: A.E.R.W.D (W) Sub-Dir. Jamnagar Urd. roadt- 27-7-21
 5) Nature of Sample: G.S.B.-I Staff: Date of Collection: 3/8/21
 6) Location: 500M. Date of Test: 5/8/21

Sl. No.	IS Sieve No.	Weight Retained	Wt of Sample Taken 23.295K			by Weight passing the Sieve (Required Value)			Remarks
			% Wt retained	% of Cumulative retained	% of passing	Grading-I	Grading-II	Grading-III	
1	75mm	—	—	—	—	100	—	—	Acceptable
2	53mm	0	0	0	100	—	100	—	
3	25mm	11135	47.79	47.79	52.21	55-75	50-80	100	
4	12mm	4274	18.34	66.13	33.87	10-30	15-35	24.15	
5	60mm	7668	32.91	99.04	0.96	0-10	<10	<10	

Copy for

- 1) Chief Engineer
 2) Sub-Engineer
 3) Asst. Engineer
 4) Regional Laboratory Division, Manikerni

By
L.A. 5/8/21

And
10/11/21

A.E.
10/11/21

10/11/21

10/11/21
 E.E.
 Regional Laboratory
 R.W.D., Purnea

OFFICE OF THE EXECUTIVE ENGINEER R.W.D. REGIONAL
LABORATORY, PURNER, (BIHAR)

RESULT OF BITMEN CONTENT OF MIX SAMPLE

Name of work Maint 7 road from Mehndibari
to Belundia Road. Name of Division Manikari
Package no./ngt.no. MR/3054 Name of Agency EXIM Buisiness world cen
Sample Collected by A.E.R.W.D(W)Sub- Div Jamnagar (4 no. credit - 27721
Location SDOM Wt. of sample taken 1000gm.

SDBC

Sl.No.	Sample No.	Identification No.	Wt. of sample b.c.	Wt. of sample a.c.	Loss wt.	Average	% of bitmen content	Remarks
1.	A.	M1	322	307	15.0			
2.	B.	M2	311	296	15.0	15.33	5.03%	
3.	C.	M3	326	310	16.0			

Acceptable

Copy to Executive Engineer RW'D (W) Div. Manikari

Suprntending Engineer _____

Chief Engineer Bihar Patna _____

1/8/21
LA

10/8/21

10/8/21

plc

10/8/2021
EXECUTIVE ENGINEER
RURAL WORKS DEPT
REGIONAL LABORATORY
PURNER.

OFFICE OF THE EXECUTIVE ENGINEER

RURAL WORKS DEPARTMENT, REGIONAL LABORATORY, PURNEA

RESULT OF PHYSICAL TEST FOR GRADATION OF COARSE AGGREGATE

NAME OF THE ROAD: Mehdi road from Mehdi Bari to Belundia road.

PACKAGE NO. UNDER P.M.G.S.Y. MR/3054

NAME OF THE WORKS DIVISION: Manikari

NAME OF WORK: WBM W II

NAME OF WORKS CIRCLE: Purnea.

NATURE OF SAMPLE: Stone metal W II

SAMPLE COLLECTED BY: A.E.R.W.D. (W) Sub-Stationary
At No. 2500-27721

NAME OF AGENCY: Exim Business world center

LOCATION: S.A.M.

SI. NO	AIV		FLAKINESS INDEX		WATER ABSORPTION		REMARKS
	TEST VALUE	REQUIRED VALUE (MAX)	TEST VALUE	REQUIRED VALUE (MAX)	TEST VALUE	REQUIRED VALUE (MAX)	
1	1	2	3	4	5	6	
1	9.6%	40%	—	—	0.71%	30%	Acceptable

SIEVE ANALYSIS FOR GRADATION OF: Stone metal W II

WEIGHT OF SAMPLE TAKEN: 1000 Kg.

SI. NO	IS SIEVE SIZE DESIGNATION IN MM	WT OF MIX RETAINED	% OF WEIGHT RETAINED	CUMULATIVE % OF WT. RETAINED	% OF WEIGHT PASSING	REQUIRED VALUE IN %	REMARKS
1	1	2	3	4	5	6	
1	63	0	0	0	100	100	
2	53	316	3.16	3.16	96.84	95-100	
3	45	2688	26.88	30.04	69.96	65-90	
4	22.4	6125	61.25	91.29	8.71	0-10	
5	11.2	780	7.80	99.09	0.91	0-5	
6							

LETTER NO.

COPY TO:-

E.E.R.W.D. WORKS DIVISION: Manikari

S.E.R.W.D. WORKS CIRCLE:

S.E. CUM STATE QUALITY CO-ORDINATOR, BIHAR, PATNA

CHIEF ENGINEER: R.W.D. BIHAR, PATNA

REGIONAL LABORATORY
R.W.D. PURNEA

REGIONAL LABORATORY
R.W.D. PURNEA

EXECUTIVE ENGINEER,
REGIONAL LABORATORY
R.W.D. PURNEA

OFFICE OF THE EXECUTIVE ENGINEER
REGIONAL LABORATORY
RURAL WORK DEPARTMENT, PURNEA
GRADATION FOR GRANULAR SUB BASE MATERIAL

- 1) Name of Work: Maint. & Repair from Mehudibari to Belunda Road.
 2) Name of Scheme: MR13054
 3) Name of Agency: Exim Business world center
 4) Sample Collected by: A.E.R.W.D (W) Sub - Div Ajamkajar (No. road - 2772)
 5) Nature of Samples: G.S.B-II
 6) Location: 500M.
- Staff:
 Date of Collection: 3/8/21
 Date of Test: 5/8/21

Sl. No.	IS Sieve Designation	Weight Retained	Wt of sample Taken: 22.615kg			Weight passing the Sieve (Required Value)			Remarks
			% Wt retained	% of cumulative retained	% of passing	Grading-I	Grading-II	Grading-III	
1	75 mm	—	—	—	—	100	—	—	Acceptable
2	53 mm	0	0	0	100	—	100	—	
3	25 mm	10929	48.32	48.32	51.68	55-75	50-80	100	
4	12.5 mm	3968	17.54	65.86	34.14	10-30	15-35	24.15	
5	6.3 mm	7508	33.15	99.05	0.95	0-10	<10	<10	

Copy for

- 1) ☐
 2) ☐
 3) ☐
 4) ☐ E.R.W.D WORKS DIVISION - Manikari

1 Copy
 L.A. 5/8/21

Accepted
 5/8/21

A.E.
 5/8/21

CNR
 5/8/21
 E.E.
 Regional Laboratory
 R.W.D., Purnea