## INSPECTION REPORT FOR ROUTINE MAINTENANCE

Date o	of Inspection:	CE
Divisio	of Inspection: 4.6.22 District: Kaimu	
Name	of the Road: Quality Length (km):	Y
Schem	on: Mohanis District: Kaimu of the Road: Pwd Road Kudra Paranthus to e  District: Kaimu Length (km): 4.15  District: Kaimu Annu Maranthus Ann	thi water
SI. No.	MK 3054	M, Kanga, Va
1.	Parameters to be checked Pavement	Remarks (S/U)
a)	Condition of Surfacing	
<b>b</b> )	Riding Quality	U
c)	Road Camber	U
d)	Whether free from defects such as visible cracks, exposed aggregates in case of CC Pavement.	
e)	Contraction Joints provided or not (CC Pavement)	-
f)	Compaction of flank/slame 8	_
Observ	Compaction of flank/slope & raincuts if any	U
wa	Some patches developed in B.T. wor v length Drepressions are existing in ter will accumulate.	which rain
2.	Cross Drainage	
a)	Condition of head walls in Hume pipe culverts including its painting	
b)	Solid of Adulment & Wing walls, Slab in RCC cultural	
c)	Condition of railings/slab/approach for Bridges	
d)	Condition of Vent Clearance	
3,	Road Furniture	
a)	Whether sign boards/informatory/cautionary Board/ km & 200m stones/Pavement road markings are provided and maintained	U
4.	Compliance History	
a)	Status of ATR's & any others	
Overall I		
	Rating : Satisfactory (S)/ Unsatisfactory (U)	U