

कार्यपालक अभियंता का कार्यालय ग्रामीण कार्य विभाग, कार्य प्रमंडल सुपौल।

पत्रांक1063(५१०)

सुपौल / दिनांक 28/07/2023

प्रेषक,

कार्यपालक अभियंता
ग्रामीण कार्य विभाग
कार्य प्रमंडल सुपौल।

सेवामें,

अपर मुख्य कार्यपालक पदाधिकारी- सह -सचिव,
नोडल पदाधिकारी,
ग्रामीण कार्य विभाग,
बिहार, पटना।

विषय:- शीर्ष MR-3054 (New Maintenance Policy-2018) योजना के अन्तर्गत
स्वीकृत योजनाओं में आवंटन हेतु अधियाचना।

महाशय,

उर्पयुक्त विषयक संदर्भ में सूचित करना है कि शीर्ष MR-3054 (New
Maintenance Policy-2018) के अन्तर्गत किये गये कार्य के भुगतान हेतु विहित प्रपत्र में
अधियाचना प्रपत्र संलग्न की जा रही है।

अतः भवदीय से अनुरोध है कि उक्त राशि उपलब्ध कराने की कृपा की जाय ताकि
संवैदक को कराये गये कार्य का भुगतान किया जा सके।

अनु०:-यथोक्त।

विश्वासभाजन

28/07/23
कार्यपालक अभियंता
ग्रामीण कार्य विभाग
कार्य प्रमंडल सुपौल।

Name of Division :- Supaul

Name of Circle :- Madhepura

Sl. No.	Package No.	Name of Road	Project ID as per MIS	Administrative Sanction Letter No & Date.	Administrative Approval (AA)		Agreement Amount (in Lac)		Agreement No. & Date	Date of Completion as per Agreement	Actual Date of Completion	Value of IRI (in mm/km)	Thickness of Bitumen Layer (in mm)	Value of Bitumen Content in Percentage	Previous Total Allocated Amount (in lakh)	up-to-date expenditure as per MIS (in Lakh)	Requisition against work done (in Lakh)	Remarks.
					Length (in km)	Amount of (in Lakh)	Initial Rectification with surface Renewal (in Lakh)	5 Years Routine Maintenance (in Lakh)										
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19
1	RM/SU/SUP/ 22/0004	Nirmali Dagenarapaki path east of screw pile bridge in tillyuga river to sikharia majhari lo bandh	21004904032	488 05.07.2022	0.992	44.882	30.18308	10.73493	52MBD/ 2022-23 Dt-20.02.23	19.11.23	Completed.	2099	25mm	5.2	0.00000	0.00000	30.14536	अवकाश राशि की मांग है।
2	RM/SU/SUP/ 22/0004	S014 to Sirkharaya Via Aakshmeta ,Mushari.	21004913013	488 05.07.2022	1.405	109.126	86.03751	13.98621			Completed.	2078	25mm	5.2	0.00000	0.00000	86.01025	अवकाश राशि की मांग है।
3	RM/SU/SUP/ 22/0013	T01 to Andauti Mushari.	21004912006	488 05.07.2022	3.085	176.95	157.84306	31.82555	53MBD/ 2022-23 Dt-20.02.23	19.11.23	Completed.	2033	25mm	5.2	0.00000	0.00000	157.81052	अवकाश राशि की मांग है।

- Signed Hard Copy and Soft Copy (in excel) of Recorded IRI is enclosed.
- Up-to-date Physical Progress has been uploaded in MIS.

Executive Engineer
Rural Works Department
Works Division Supaul
28/07/23

***FORM GFR 19-A**
(See Government of India's decision (I) below rule- 150)
Form of Utilization certificate up to the month July 2023
PIU:- E.E RWD(W)DIV-Supaul

SL.NO.	Name of Schemes	Sanction No.& Date with Amount (In Lacs)	Amount received (In Lacs)	Particulars
1	2	3	4	5
1	New Maint. Policy-2018 (MR)	Lt.No-40 Dt-14.06.2021 Lt.No-52 Dt-24.08.2021 Lt.No-60 Dt-09.11.2021 Lt.No-05Dt-25.01.2022 Lt.No-20Dt-14.03.2022 Lt.No-35Dt-14.03.2023 Lt.No-72Dt-10.05.2023	2352.94029	Certified that out of Rs. 2352.94029 Lacs of grants-in-aid sanctioned during the years 2023-24 in favour of Executive Engineer R. W. D. Works Division, Supaul a sum of Rs 1891.02348 Lacs has been utilized for the purpose of New Maint. Policy 2018 Schemes as given in the margin for which it was sanctioned and that the balance of Rs. 461.91681 Lac remaining unutilized at the end of the period under report.
		TOTAL	2352.94029	

2. Certified that I have satisfied myself that the conditions on which the grant-in-aid was sanctioned have been duly fulfilled, are being fulfilled and that I have exercised the following checks to see that the money was actually utilized for the purpose for which it was sanctioned.

Kinds of checks exercised:-

- Works has been supervised by Executive Engineer / Superintending Engineer.
- Periodic as inspection has been conducted by Executive Engineer / Superintending Engineer.
- Construction materials have been tested.
- Measurements have been recorded in the MBs and test check conducted by the Assistant Engineer / Executive Engineer.
- All other codal formalities have been observed.

3. Physical Progress achieved:-

- Construction of Road Works.
- Construction of CD Works.

Selu
28-07-23
DIVISIONAL ACCOUNTS OFFICER

R.W.D. Works Division, SUPAUL

quail
28/07/23
EXECUTIVE ENGINEER

quail
R.W.D. Works Division, SUPAUL

Name of work : T01 To Andauli Musharhi

Name of customer : Vija Kumar Jha

(R)Rural Road

Good

Average

Poor

< 4000

4001 - 5000

> 5000

Date	Time	Test No	Distance(m)	Total Distance(m)	BUM(1cm)	Speed(Km/Hr)	U(1mm/Km)	Corrected U (mm/Km)	IRI	Status	Latitude	Direction	Longitude	Direction1	Remarks
27/07/23	19:47:16	30	0	0	0.0 cm	15.6 Km/Hr	0.0 mm/Km	216	0.38	Good	26.1028204	N	86.6530313	E	Normal
27/07/23	19:48:05	30	100	100	27.0 cm	2.8 Km/Hr	2700.0 mm/Km	2721	3.69	Good	26.3859148	N	86.7168970	E	Normal
27/07/23	19:48:30	30	100	200	27.0 cm	14.4 Km/Hr	2700.0 mm/Km	2721	3.69	Good	26.3862848	N	86.7158518	E	Normal
27/07/23	19:48:53	30	100	300	30.0 cm	15.7 Km/Hr	3000.0 mm/Km	3000	4.03	Good	26.3872805	N	86.7152338	E	Normal
27/07/23	19:49:19	30	100	400	27.0 cm	13.9 Km/Hr	2700.0 mm/Km	2721	3.69	Good	26.3872805	N	86.7152338	E	Normal
27/07/23	19:49:43	30	100	500	29.0 cm	15.3 Km/Hr	2900.0 mm/Km	2907	3.92	Good	26.3872805	N	86.7152338	E	Normal
27/07/23	19:50:00	30	100	600	28.0 cm	20.7 Km/Hr	2800.0 mm/Km	2814	3.81	Good	26.3893232	N	86.7158050	E	Normal
27/07/23	19:50:16	30	100	700	18.0 cm	22.5 Km/Hr	1800.0 mm/Km	1886	2.96	Good	26.3896418	N	86.7166986	E	Normal
27/07/23	19:50:33	30	100	800	12.0 cm	21.4 Km/Hr	1200.0 mm/Km	1329	1.95	Good	26.3905401	N	86.7168283	E	Normal
27/07/23	19:50:48	30	100	900	14.0 cm	21.6 Km/Hr	1400.0 mm/Km	1515	2.19	Good	26.3913622	N	86.7171106	E	Normal
27/07/23	19:51:05	30	100	1000	18.0 cm	22.9 Km/Hr	1800.0 mm/Km	1886	2.86	Good	26.3919859	N	86.7175608	E	Normal
27/07/23	19:51:20	30	100	1100	16.0 cm	23.9 Km/Hr	1600.0 mm/Km	1701	2.43	Good	26.3922205	N	86.7181330	E	Normal
27/07/23	19:51:34	30	100	1200	26.0 cm	25.2 Km/Hr	2600.0 mm/Km	2629	3.58	Good	26.3930788	N	86.7183924	E	Normal
27/07/23	19:51:49	30	100	1300	20.0 cm	23.8 Km/Hr	2000.0 mm/Km	2072	2.89	Good	26.3938360	N	86.7189349	E	Normal
27/07/23	19:52:04	30	100	1400	24.0 cm	24.1 Km/Hr	2400.0 mm/Km	2443	3.35	Good	26.3935671	N	86.7197590	E	Normal
27/07/23	19:52:20	30	100	1500	16.0 cm	23.8 Km/Hr	1600.0 mm/Km	1701	2.43	Good	26.3946104	N	86.7206888	E	Normal
27/07/23	19:53:01	30	100	1600	13.0 cm	8.8 Km/Hr	1300.0 mm/Km	1422	2.07	Good	26.3952894	N	86.7208338	E	Normal
27/07/23	19:53:19	30	100	1700	19.0 cm	20.6 Km/Hr	1900.0 mm/Km	1979	2.78	Good	26.3961363	N	86.7213678	E	Normal
27/07/23	19:53:35	30	100	1800	16.0 cm	22.0 Km/Hr	1800.0 mm/Km	1701	2.43	Good	26.3968592	N	86.7216959	E	Normal
27/07/23	19:53:50	30	100	1900	12.0 cm	23.4 Km/Hr	1200.0 mm/Km	1329	1.95	Good	26.3975668	N	86.7221384	E	Normal
27/07/23	19:54:07	30	100	2000	20.0 cm	22.0 Km/Hr	2000.0 mm/Km	2072	2.89	Good	26.3981771	N	86.7225580	E	Normal

Name of work : T01 To Andauli Musharhi

Name of customer : Vija Kumar Jha

(R)Rural Road			
Good		Average	Poor
< 4000		4001 - 5000	> 5000

27/07/23	19.54.29	30	100	2100	19.0 cm	16.5 Km/Hr	1900.0 mm/Km	1979	2.78	Good	26.3995047	N	86.725275	E	Normal
27/07/23	19.54.55	30	100	2200	14.0 cm	13.1 Km/Hr	1400.0 mm/Km	1515	2.19	Good	26.4002867	N	86.7228327	E	Normal
27/07/23	19.55.17	30	100	2300	15.0 cm	16.6 Km/Hr	1500.0 mm/Km	1608	2.31	Good	26.4008017	N	86.7238626	E	Normal
27/07/23	19.55.41	30	100	2400	22.0 cm	15.4 Km/Hr	2200.0 mm/Km	2257	3.13	Good	26.4012832	N	86.7242385	E	Normal
27/07/23	19.56.00	30	100	2500	22.0 cm	18.8 Km/Hr	2200.0 mm/Km	2257	3.13	Good	26.4020281	N	86.7250299	E	Normal
27/07/23	19.56.38	30	100	2600	20.0 cm	9.5 Km/Hr	2000.0 mm/Km	2072	2.89	Good	26.4028254	N	86.7250833	E	Normal
27/07/23	19.56.55	30	100	2700	15.0 cm	20.8 Km/Hr	1500.0 mm/Km	1608	2.31	Good	26.4039679	N	86.7250681	E	Normal
27/07/23	19.57.10	30	100	2800	15.0 cm	23.9 Km/Hr	1500.0 mm/Km	1608	2.31	Good	26.4048433	N	86.7250581	E	Normal
27/07/23	19.57.39	30	100	2900	22.0 cm	12.7 Km/Hr	2200.0 mm/Km	2257	3.13	Good	26.4057455	N	86.7250299	E	Normal
27/07/23	19.58.11	30	100	3000	36.0 cm	11.4 Km/Hr	3600.0 mm/Km	3557	4.69	Good	26.4067888	N	86.7252283	E	Normal

Flex Control
Customer: Vija Kumar Jha , Machine no: 19187 , Road: T01 To Andauli Musharhi , Date: 27-07-23 , Section No: 30 , Equation: $Y=0.928X+215.8$

