

कार्यपालक अभियन्ता का कार्यालय
ग्रामीण कार्य विभाग, कार्य प्रमण्डल, सहरसा

पत्रांक..66.315.../

सहरसा, दिनांक..13-01-2024.. /

प्रेषक:—

कार्यपालक अभियन्ता,
ग्रामीण कार्य विभाग,
कार्य प्रमण्डल, सहरसा।

सेवा में,

नोडल पदाधिकारी,
3054 (M.R) कोषांग,
बिहार, पटना।

विषय:—

शीर्ष 3054 नई अनुरक्षण नीति-2018 अंतर्गत Initial Rectification and Surface renewal. कराये गये कार्य हेतु अधियाचना के संबंध में।

महाशय,

उपर्युक्त विषयक कहना है कि विहित प्रपत्र में संलग्न विवरणी के अनुसार शीर्ष Mr 3054 New Maintenance Policy-2018. अन्तर्गत Kachra Pradhanmantri Main Sadak To Nathu Yadav House पथ का Initial Rectification and Surface renewal. कराये गये कार्य हेतु राशि Rs.60.32421/- (रूपये साठ लाख बत्तीस हजार चार सौ इकीस मात्र) राशि की आवश्यकता है।

अतः कार्यहित में अनुरोध है कि उक्त अधियाचित राशि Rs.60.32421/- (रूपये साठ लाख बत्तीस हजार चार सौ इकीस मात्र) उपलब्ध कराने की कृपा की जाय ताकि कराये जा रहे कार्यों का विपत्र भुगतान किया जा सके।

- अनु०:— (1) अधियाचना प्रपत्र
(2) IRI Value Report
(3) Map
(4) प्रमाण-पत्र।

विश्वासभाजन

BS
13/1/24

13-01-2024
कार्यपालक अभियन्ता
गा0का0वि०, कार्य प्रमण्डल,
सहरसा

Rural Works Department
MR NEW MAINTENANCE POLICY-2018. ALLOTMENT REQUISITION

Name of Division - RWD Works Division Saharsa

SL No.	Year	Name of Road	Name of Contractor (In English)	Project Id	Administrative Sanction		Agreement Amount (In Lacs)		Value of IRI (in mm/km)	Thickness of Bitumen Layer (in mm)	Value of Bitumen Content in Percentage	Allotment Received (in Lacs)	Total Expenditure as per MIS (in Lacs)	Value of Measurement (in Lacs)	Current Demand (in Lacs)	Remarks
					Length (In Km)	Amount (In Lacs)	Main Work	Maintenance								
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17
59	2022-23	KACHYA PRASHANTNAGRI Main Sadak To Nuthu Yadav house	Arvind Kumar	20904313023	2.000	116.75000	84.56945	26.17255	2724	25	5%	24.24524	24.24524	84.56945	60.32421	Complete

B.K. S. S.
12/1/24
D.A.O.
RWD Works Division
Saharsa

B.K. S. S.
13-01-2024
Executive Engineer
RWD Works Division
Saharsa

**OFFICE OF THE EXECUTIVE ENGINEER
RWD WORKS DIVISION SAHARSA.**

Name of Scheme:- Kachra Pradhanmantri Main Sadak To Nathu Yadav House, PACKAGE No-
RM/SA/SAH/22/0008, Project ID- 20904313023.


Certified that all item wise 100%
Measurement has been taken by me


Junior Engineer
RWD Work section Saurbazar
Works Division Saharsa

Certified that all item wise 50%
Measurement has been checked by me


Assistant Engineer
RWD Work Section Saurbazar
Works Division Saharsa

Certified that all item wise 10%
Measurement has been checked by me


Executive Engineer
Rural work Department
Works Division Saharsa

Name of Road - Kachra Pradhanmantri Main Sadak To Nathu Yadav House

Name of Contractor Arvind Kumar			Batch Name -RM/SA/SAH/22/0008								
Date	Time	Section	Length	Bumps	Speed	OR	IRI	CATEGORY	Latitude	Longitude	Event
		No.	in km	in mm	Rate	mm/km	mm/km	ROAD			
17-11-2023	10:54:13	97	0.100	180	10.1	2000	2478	G	25.800368	86.711203	Normal
17-11-2023	10:54:34	97	0.100	270	10.1	2700	3167	G	25.801195	86.711878	Normal
17-11-2023	10:55:00	97	0.100	180	10.1	2000	2478	G	25.801415	86.712632	Normal
17-11-2023	10:55:14	97	0.100	270	10.1	2700	3167	G	25.801482	86.712702	Normal
17-11-2023	10:55:25	97	0.100	210	10.1	2100	2577	G	25.802508	86.713990	Normal
17-11-2023	10:56:00	97	0.100	180	10.1	2000	2478	G	25.802508	86.713849	Normal
17-11-2023	10:56:34	97	0.100	270	10.1	2700	3167	G	25.804775	86.716580	Normal
17-11-2023	10:57:09	97	0.100	180	10.1	2000	2478	G	25.804899	86.716580	Normal
17-11-2023	10:57:21	97	0.100	180	10.1	2000	2478	G	25.804899	86.716580	Normal
17-11-2023	10:58:02	97	0.100	270	10.1	2700	3167	G	25.804771	86.716691	Normal
17-11-2023	10:58:37	97	0.100	180	10.1	2000	2478	G	25.804335	86.717182	Normal
17-11-2023	10:59:08	97	0.100	200	10.1	2000	2478	G	25.803934	86.717344	Normal
17-11-2023	10:59:45	97	0.100	180	10.1	2000	2478	G	25.80364	86.717646	Normal
17-11-2023	11:00:04	97	0.100	270	10.1	2700	3167	G	25.803181	86.717646	Normal
17-11-2023	11:00:29	97	0.100	180	10.1	2000	2478	G	25.803735	86.719990	Normal
17-11-2023	11:01:07	97	0.100	270	10.1	2700	3167	G	25.804692	86.721010	Normal
17-11-2023	11:01:48	97	0.100	180	10.1	2000	2478	G	25.804358	86.720472	Normal
17-11-2023	11:01:57	97	0.100	270	10.1	2700	3167	G	25.803776	86.720147	Normal
17-11-2023	11:02:15	97	0.100	200	10.1	2000	2478	G	25.804567	86.720576	Normal
17-11-2023	11:02:38	97	0.100	180	10.1	2000	2478	G	25.805278	86.720876	Normal
						Total	54482.0				
						Average	2724.10				

$$Y = 0 * X^2 + 0.984 * X + 510.7$$



$$X =$$

$$Y = 2577$$

(R) RURAL ROAD

Good Average Poor

<4000 4001-5000 >5001

 12/01/2024
 12/01/24
 13-01-2024

Steco Analyzer

Name of Customer : Arvind Kumar
Name of Work/ Road : Sadak To Nathu Yadav House
Lab Job number :
Date : 11/17/2023
Section No. : 97


Test Date : 11/17/2023 Road Name : Sadak To Nathu Yadav House
Machine No : 403 Road Type : (A) ASPHALTIC
Start S No : Side :
Start E No : Interval
Weather : UIV Range : 1478 To 4000 1000 mm/km
Start Location : Dist Range : 0 To 2.1 0.1 * 1000 m
End Location : Equation : test

Print

Generate Report and Graph

Redraw Graph

Map View



12/01/2024
52

12/01/24

13-01-2024