

सहायक अभियंता का कार्यालय

ग्रामीण कार्य विभाग, जाँच एवं गुणवत्ता नियंत्रण प्रयोगशाला, वीरपुर ।

Email ID:- tqclab-virpur25@bihar.gov.in

पत्रांक:- 42 / वीरपुर

दिनांक:- 22 / 12 / 2025

प्रेषक,

सहायक अभियंता,
ग्रामीण कार्य विभाग,
जाँच एवं गुणवत्ता नियंत्रण प्रयोगशाला, वीरपुर ।

सेवा में,

कार्यपालक अभियंता
ग्रामीण कार्य विभाग,
कार्य प्रमंडल, वीरपुर ।

विषय:- पथों में किए गए जाँच फल के संबंध में ।

प्रसंग:- कार्यपालक/सहायक अभियंता का पत्रांक 00 दिनांक 18 / 11 / 2025
महाशय

उपरोक्त विषयांकित संदर्भ में कहना है कि आपके प्रमंडलाधीन निर्माण कराए जा रहे पथों/पूल-पुलियों में प्रयुक्त किए जा रहे सामग्रियों के नमूने को जाँचोंपरांत जाँच प्रतिवेदन सलग्न कर भेजा जा रहा है, जो निम्नवत है ।

पथ/पूल का नाम:- CONT. OF ROAD FROM NH-106 KARJAIN
PANCHAIAT TO SITAPUR SHATANPATI EAST KOSHI
TATDAND 17 KM.

योजना:- RRSM-2

संवेदक:- M/S CHANSHYAM LAL.

नमूना:- PCC-M-35

स्वीकृत/अस्वीकृत:- स्वीकृत

विश्वासभाजन

81/8
22/12/25

सहायक अभियंता

जाँच एवं गुणवत्ता नियंत्रण प्रयोगशाला,
ग्रामीण कार्य विभाग, वीरपुर ।

TESTING AND QUALITY CONTROL LABORATORY

RURAL WORKS DEPARTMENT, VIRPUR

Email ID:- tqclab-virpur25@bihar.gov.in

TEST RESULT OF CONCRETE CUBE

CUBE TEST OF:- M-35

SCHEME:- RRSMP-2

NAME OF DIVISION:- R.W.D, WORKS DIVISION VIRPUR

NAME OF WORK:- CONT. OF ROAD FROM NH-106 KARJAIN PANCHAYAT TO SITAPUR SATANPATIL EAST KOSHI TAT BAND 17 KM.

NAME OF AGENCY:- M/S CHANSHYAM LAL

REF:- SAMP. COLLECTED BY R.E LETTER NO:- OD DATE:- 18/11/2025

CH:-

DATE OF TEST:- 22/12/2025

SL No.	<u>CUBE TEST ON 28 DAYS</u>				Remarks
	1	2	3	4	5
1	Date Of Concreting	<u>18-11-25</u>	<u>18-11-25</u>	<u>18-11-25</u>	PERMISSIBLE
2	Date Of Test	<u>22-12-25</u>	<u>22-12-25</u>	<u>22-12-25</u>	
3	ID. Mark	<u>B1</u>	<u>B2</u>	<u>B3</u>	
4	Area (CM2)	<u>225</u>	<u>225</u>	<u>225</u>	
5	Maximum Load (KN)	<u>787</u>	<u>784</u>	<u>789</u>	
6	Crushing Strength (Kg/CM2)	<u>356.695</u>	<u>355.316</u>	<u>357.582</u>	
7	Mix Design M- <u>35</u>				

OK
22/12/2025
Technical Supervisor

Testing & Quality
Control Laboratory, R.W.D
Virpur

SLP
22/12/25
Assistant Engineer

Testing & Quality
Control Laboratory, R.W.D
Virpur