

OFFICE OF THE ASSISTANT ENGINEER
R.W.D, TESTING & QUALITY CONTROL LABORATORY, ARARIA

Name Of Project/ Road :- Binnatpur To Tarachand Saha House (Fakir Tola)

Name Of Scheme :- RRSMP

Name Of Agency:- Dooars Construction Company

Nature Of Sample :- Concrete Cube

Location :- Sample

Date of Coll./Rec. in Lab :- 04/10/2025

Date of Test :- 04/10/2025


Agreement No./ Package No. :- 03/CMBD/2025-26

Ref :- Material Send By A.E, R.W.D Works Div. Araria Vide Lett. No. 0- Dt. 09-07-2025

S. No.	Description								Test 28 Days		
	Date of concreting	Member under construction	Proportion of mix/grade	Identification of marks	Area of mould (cm2)	Load of initial crackng (KN)	Maximum load (KN)	Crushing strength (KN/CM 2)	Average crushing strength (KN/MM 2)	Required crushing strength (KN/MM 2)	Remarks
1	2	3	4	5	6	7	8	9	10	11	
1	30-06-2025	PQC PAVEMENT	As Per Mix Design M35	PCC-1	225	-	849.00	3.773	38.06	35.70	Permissible
2	30-06-2025	PQC PAVEMENT	As Per Mix Design M35	PCC-2	225	-	858.00	3.813			
3	30-06-2025	PQC PAVEMENT	As Per Mix Design M35	PCC-3	225	-	862.00	3.831			

Nitish Kumar
04/10/25
TS

MA
04/10/25
T.S


4/10/25
Assistant Engineer
RWD
Testing & Quality Control Laboratory, Araria