

OFFICE OF THE ASSISTANT ENGINEER
R.W.D, TESTING & QUALITY CONTROL LABORATORY, ARARIA

Name Of Project/ Road :- House Of Tajuddin To Nahar Road Istama Tola

Name Of Scheme :-RRSMP

Name Of Agency:- DOOARS CONSTRUCTION COMPANY

Nature Of Sample :-Concrete Cube

Date of Coll./Rec. in Lab :- 23/09/2025

Location :- Sample

Date of Test :-

23/09/2025

Agreement No./ Package No. :- 03/CMBD/2025-26

Ref :- Material Send By A.E, R.W.D Works Div. Araria Vide Lett. No. 0- Dt. 03-07-2025

S. No.	Test 28 Days										Remarks
	Date of concreting	Member under construction	Proportion of mix/grade	Identification of marks	Area of mould (cm2)	Load of initial cracking (KN)	Maximum load (KN)	Crushing strength (KN/CM 2)	Average crushing strength (KN/MM 2)	Required crushing strength (KN/MM 2)	
1	2	3	4	5	6	7	8	9	10	11	
1	23-06-2025	PQC PAVEMENT	As Per Mix Design M35	PCC-1	225	-	875.00	3.889	38.81	35.70	Permissible
2	23-06-2025	PQC PAVEMENT	As Per Mix Design M35	PCC-2	225	-	865.00	3.844			
3	23-06-2025	PQC PAVEMENT	As Per Mix Design M35	PCC-3	225	-	880.00	3.911			

Nitish Kumar
23/09/25
TS

23/09/25
T-S

Copy
23/9/25
Assistant Engineer
RWD

Testing & Quality Control Laboratory, Araria