

OFFICE OF THE ASSISTANT ENGINEER
R.W.D, TESTING & QUALITY CONTROL LABORATORY, ARARIA

Name Of Project/ Road :- Kullehayat Salehat School To House Of Kudas

Name Of Scheme :- RRSMP

Name Of Agency:- Dooars Construction Company

Nature Of Sample :-Concrete Cube

Location :- Sample

Date of Coll./Rec. in Lab :- 06/10/2025

Date of Test :- 06/10/2025

Agreement No./ Package No. :- 03/CMBD/2025-26

Ref :- Material Send By A.E, R.W.D Works Div. Araria Vide Lett. No. 0/Camp- Dt. 30-06-2025

S. No.	Description								Test 28 Days			Remarks
	Date of concreting	Member under construction	Proportion of mix/grade	Identification of marks	Area of mould (cm ²)	Load of initial cracking (KN)	Maximum load (KN)	Crushing strength (KN/CM ²)	Average crushing strength (KN/MM ²)	Required crushing strength (KN/MM ²)		
1	2	3	4	5	6	7	8	9	10	11		
1	21-06-2025	PQC PAVEMENT	As Per Mix Design M35	PCC-1	225	-	855.00	3.800	38.21	35.70	Permissible	
2	21-06-2025	PQC PAVEMENT	As Per Mix Design M35	PCC-2	225	-	859.00	3.818				
3	21-06-2025	PQC PAVEMENT	As Per Mix Design M35	PCC-3	225	-	865.00	3.844				

Nitish Kumar
06/10/25
T.S

AA
06/10/25
T.S

Cupte
06/10/25
Assistant Engineer
RWD

Testing & Quality Control Laboratory, Araria